

**Office of the President
of the Philippines
Malacañang**

BID BULLETIN

Pursuant to the Invitation to Bid published last 16 May 2019 in PhilGEPS, OP-website and three conspicuous places regarding the Project – **Consulting Services for the Structural Investigations and Detailed Engineering for the Repair and Strengthening/Retrofitting of the New Executive Building** with Purchase Request (PR) No. 18-12-1628, please be informed of the following changes approved by the Bids and Awards Committee (BAC) during the Pre-bid Conference held on 23 May 2019, 10:00 AM,, at the OP-BAC Bidding Room, Mezzanine Flr., Mabini Hall Building, Malacañang, Manila; in accordance with the amendments/changes in the Bidding Documents recommended by the End-user as follows:

PARTICULARS	FROM	TO
(Under Terms of Reference) 5. Scope of Services	5.1.10 The Consultant shall conduct geotechnical investigation of at least three (3) boreholes to determine the soil bearing capacity, liquefaction potential, and settlement.	5.1.10 The Consultant shall conduct geotechnical investigation of at least two (2) boreholes to determine the soil bearing capacity, liquefaction potential, and settlement.
(Under Section VII. Bidding Forms) TF2. Consultant's References	Approx. Value of Services (in Current US\$):	Approx. Value of Services (in Current PHP):
(Under Section VII. Bidding Forms) Eligibility Documents Submission Form	Attached Form	Disregard

Moreover, with respect to queries submitted to the end-user, please be informed of the following clarifications:

- 1) The minimum depth of the bore hole is at least **thirty (30) meters**; and
- 2) To forego with the footing/foundation investigation is not acceptable. The structural investigation should cover all structural components of the building such as the foundation, columns, beams, slab, and walls. The Engineering Office has identified two (2) representative footings for both main and annex buildings. The top surface of the said footing is at the same level with the basement floor.

Please be guided accordingly.


Atty. RYAN ALVIN R. ACOSTA
Chairman, OP – Bids and Awards Committee

04 June 2019
GMB/OP-BACSEC